

Liteplan's emergency products are fitted with a charge indicating LED.

A Solid Green light indicates that the Battery Charge is healthy.

Self-Test and DALI emergency products are fitted with a Bi-Colour LED and indicate as follows:

- A **Solid Green light** indicates that the Battery Charge is healthy.
- A **Green Flashing light** indicates that the unit is in pre-commissioning mode, or there is either a Function or Duration Test in progress or that a test has taken place recently
- A **Red Flashing or Red Solid light** indicates that there is a fault on the unit.



Please refer to following chart below for more complete descriptions/fault indication:-

		Model			
		ADM	HALO Surface	TNA	DNA
LED Indicates					
Green Solid	Mains On No Fault	●	●	●	●
	48h Pre- Commissioning	○	○	○	○
Green Flash	Function Test In Progress	○	○	○	○
	Duration Test In Progress	○	○	○	○
	Duration Test Passed	○	○	Not Applicable	Not Applicable
Red Flash	Battery Fault	●	●	●	●
	Lamp Fault	●	●	●	●
LED Off	Mains Failure Battery OK	○ Off	○ Off	○ Off	○ Off
Red/Green Alternate	DALI Mode Identification	●	●	●	●
Self-test only					
Red/Green Alternate	Commissioning Test Time-out	Not Applicable	Not Applicable	●	●

NB: The above self-test time-out indicates that the control gear has not received permanent power for an uninterrupted period of 24 hours for 7 days. This only shows in self-test mode, not DALI.