

Installation & Wiring Instructions

BNM/1

Non- Maintained Emergency Driver



PLEASE READ THESE INSTRUCTIONS BEFORE COMMENCING INSTALLATION & LEAVE WITH END USER


Description:

The BNM/1 is a standalone 3 hour non-maintained emergency driver. The LED load is driven at 700mA.

The batteries used with this kit are lithium iron phosphate (LiFePO₄) which not only last double the life of traditional emergency lighting batteries, but consume far less power.

The battery is fitted with a PCM to protect the supply voltage against reverse polarity.

The product features battery temperature protection in accordance with IEC 61347-2-7: 2012+A12:2022.



Fixing Centres 129mm

Specification:

Input Voltage	230-240 Volts AC 50/60 Hz
Input Current & PF - standby	0.2W 8mA - $\lambda = 0.11$
Input Current & PF - charging	1.7W 14mA - $\lambda = 0.5$
Insulation between supply & battery	Double Reinforced
Duration	3-hours
Maximum Module Tc	70°C
Minimum Battery Tc	0°C
Maximum Battery Tc	55°C
Terminal Blocks	0.5-1.5mm ² Push Wire
Battery Fuse	Internal
Battery Discharge Current	900mA Nominal
Discharge Voltage Limit	2.5V
Ingress Protection	IP20
Battery Pack	3.2V 3.8Ah LiFePO ₄
Charge Current	225mA Nominal
Recharge Period	24-Hours
Module Size (L x W x H)	135mm x 30mm x 21mm
Module Fixing Centers	129mm
Module Weight	0.10Kg
Battery Details (mm)	Stick 90mm x 28mm x 26.5mm
Battery Fixing Centres	80mm
Battery Weight	0.11Kg

BNM/1

700mA Non-Maintained Emergency Driver for Single LED Loads
Open Circuit Voltage (U-OUT) = 4 Volts

Important

It is recommended that the module is installed by a competent person ensuring the installation complies with the necessary standards. Liteplan accept no responsibility for injury, damage or loss, which may arise as a result of incorrect installation, operation or maintenance.

The conversion requires an unswitched supply for charging the battery and a switched supply if the unit is being used for maintained operation.

ISOLATE BOTH MAINS SUPPLIES AND DISCONNECT THE BATTERY BEFORE INSTALLATION OR MAINTENANCE.

Installation

When converting a luminaire observe the following points:-

1. Fit the module & battery pack into the existing luminaire ensuring that they will operate within their temperature ratings.
2. If the module & battery pack do not fit integrally, then a remote conversion can be used. Ensure that the interconnecting loom is kept as short as possible.
3. Wire the module & battery to the dedicated emergency load as per wiring diagram on Pg2.
4. Ensure that the Permanent Live feed is connected correctly.
5. Arrange the wiring to avoid running the 240 Volt cables next to the modules output to the LED to obtain the best EMC results.
6. Requirements for 'F' markings must be observed.
7. Identify clearly the NEW Un-switched supply.
8. Ensure the LED Charge Indicator is clearly visible.
9. If fitted within a metal enclosure, connect earth terminal to metal gear tray for improved EMC.
10. This module is not intended for use in luminaires for high-risk task area lighting.
11. This module is protected against battery polarity reversal.


Installation & Wiring Instructions

BNM/1
Non-Maintained Emergency Driver



PLEASE READ THESE INSTRUCTIONS BEFORE COMMENCING INSTALLATION & LEAVE WITH END USER

Typical
Conversion
Wiring Diagram



Luminaire Ref/Location			In Case of difficulty, contact the Installation Engineers:- Tel: _____							
Full Recharge Time 24 Hours			Duration 3 Hours				Lamp Type - LED			
ROUTINE TEST RECORD										
	Year 1		Year 2		Year 3		Year 4		Year 5	
Monthly Test	Signed	Date	Signed	Date	Signed	Date	Signed	Date	Signed	Date
Functional										
Functional										
Functional										
Functional										
Functional										
Functional										
Functional										
Functional										
Functional										
Functional										
Three Hour										

